



■ ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES CONFIGURATION: FOR SPECIFIC CONFIGURATION, CALL JENSEN PRECAST.

MINIMUM EXCAVATION SIZE:
4'-5" x 7'-10" x DEPTH REQUIRED.

- (A) 6" TOP SECTION WT.= 230 Lbs.
- (B) 6" EXTENSION SECTION (OPTIONAL NOT SHOWN)
- (C) INTERMEDIATE SECTION WT.= 1,220 Lbs.
- (D) BASE SECTION WT.= 1,700 Lbs.
- (E) 14" X 14" X 14" DEEP DUCT KNOCKOUT EACH END
- (F) 8" X 16" KNOCKOUT - TWO EACH SIDE
- (G) SUMP - VARIOUS SIZES AVAILABLE
- (H) FOR COVERS: SEE COVER AND NECKING SECTION.
- (I) PULLING IRON

- DESIGNED FOR PEDESTRIAN OR LIGHT TRAFFIC LOADING.
- ASSEMBLY TO BE PLACED ON A 6" BASE OF CRUSHER RUN FOR EASE OF INSTALLATION AND EVEN LOAD DISTRIBUTION.
- MINIMUM HEADROOM IS 3'-0". ADDITIONAL DEPTHS ARE AVAILABLE BY EXTENSION SECTIONS.

**2'-6" x 4'-0" VARIABLE
DEPTH INTERCEPT
PULL BOX**



3048 DIB

ORG. DWG. DATE 10-24-00	REV. DWG. DATE
-----------------------------------	----------------