



■ ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES CONFIGURATION: FOR SPECIFIC CONFIGURATION, CALL JENSEN PRECAST.

MINIMUM EXCAVATION SIZE:
3'-8" x 7'-0" x DEPTH REQUIRED.

- (A) 6" TOP SECTION WT.= 230 Lbs.
- (B) 6" EXTENSION SECTION (OPTIONAL) WT.= 330 Lbs.
- (C) BOTTOM SECTION WT.= 2,500 Lbs.
- (D) 14" X 14" X 12" DEEP DUCT KNOCKOUT EACH END
- (E) 8" x 16" KNOCKOUT - TWO EACH SIDE
- (F) 6" DIA. SUMP KNOCKOUT
- (G) FOR COVERS: SEE COVER AND NECKING SECTION.
- (H) PULL IRON

- DESIGNED FOR PEDESTRIAN OR LIGHT TRAFFIC LOADING.
- ASSEMBLY TO BE PLACED ON A 6" BASE OF CRUSHER RUN FOR EASE OF INSTALLATION AND EVEN LOAD DISTRIBUTION.
- MINIMUM HEADROOM IS 3'-0". ADDITIONAL DEPTHS ARE AVAILABLE BY EXTENSION SECTIONS.

2'-6" x 4'-0" VARIABLE DEPTH PULL BOX	
ORG. DWG. DATE 10-24-00	REV. DWG. DATE



3048 DPB