



■ ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES CONFIGURATION: FOR SPECIFIC CONFIGURATION, CALL JENSEN PRECAST.

MINIMUM EXCAVATION SIZE:
3'-6" x 6'-4" x DEPTH REQUIRED.

- Ⓐ 6" TOP SECTION WT.= 200 Lbs.
- Ⓑ 6" EXTENSION SECTION (OPTIONAL NOT SHOWN)
- Ⓒ INTERMEDIATE SECTION WT.= 950 Lbs.
- Ⓓ BASE SECTION WT.= 1450 Lbs.
- Ⓔ 11" X 11" X 13 1/2" DEEP DUCT KNOCKOUT EACH END
- Ⓕ 8" X 16" KNOCKOUT - TWO EACH SIDE
- Ⓖ 6" DIA. SUMP KNOCKOUT
- Ⓗ FOR COVERS: SEE COVER AND NECKING SECTION
- Ⓘ PULL IRON

- DESIGNED FOR PEDESTRIAN OR LIGHT TRAFFIC LOADING.
- ASSEMBLY TO BE PLACED ON A 6" BASE OF CRUSHER RUN FOR EASE OF INSTALLATION AND EVEN LOAD DISTRIBUTION.
- MINIMUM HEADROOM IS 3'-0". ADDITIONAL DEPTHS ARE AVAILABLE BY EXTENSION SECTIONS.

2'-0" x 3'-0" VARIABLE DEPTH INTERCEPT PULL BOX	
ORG. DWG. DATE 10-24-00	REV. DWG. DATE



2436 DIB