



MINIMUM EXCAVATION SIZE:
3'-2" x 6'-0" x DEPTH REQUIRED.

■ ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES
CONFIGURATION: FOR SPECIFIC CONFIGURATION,
CALL JENSEN PRECAST.

- (A) 6" TOP SECTION WT.= 200 Lbs.
- (B) 6" EXTENSION SECTION (OPTIONAL NOT SHOWN)
- (C) BOTTOM SECTION WT.= 1,955 Lbs.
- (D) 11" X 11" X 13 1/2" DEEP DUCT KNOCKOUT EACH END
- (E) 8" x 16" KNOCKOUT-TWO EACH SIDE
- (F) 6" DIA. SUMP KNOCKOUT
- (G) FOR COVERS: SEE COVER AND NECKING SECTION
- (H) PULL IRON

- DESIGNED FOR PEDESTRIAN OR LIGHT TRAFFIC LOADING.
- ASSEMBLY TO BE PLACED ON A 6" BASE OF CRUSHER RUN FOR EASE OF INSTALLATION AND EVEN LOAD DISTRIBUTION.
- MINIMUM HEADROOM IS 3'-0". ADDITIONAL DEPTHS ARE AVAILABLE BY EXTENSION SECTIONS.

2'-0" x 3'-0" VARIABLE DEPTH PULL BOX		JENSEN PRECAST®
ORG. DWG. DATE 10-24-00	REV. DWG. DATE	
		2436 DPB