



MINIMUM EXCAVATION SIZE:  
5'-2" x 5'-2" x DEPTH REQUIRED.

■ ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES CONFIGURATION: FOR SPECIFIC CONFIGURATION, CALL JENSEN PRECAST.

- Ⓐ 6" TOP SECTION WT.= 400 Lbs.
- Ⓑ 6" & 12" EXTENSION SECTIONS (OPTIONAL NOT SHOWN)
- Ⓒ BOTTOM SECTION WT.= 3,000 Lbs.
- Ⓓ 20" x 20" KNOCKOUT - EACH END
- Ⓔ 8" x 16" KNOCKOUT - TWO EACH SIDE
- Ⓕ 8" DIA. SUMP KNOCKOUT
- Ⓖ FOR COVERS: SEE COVER AND NECKING SECTION.
- Ⓗ PULL IRON

- DESIGNED FOR PEDESTRIAN OR LIGHT TRAFFIC LOADING.
- ASSEMBLY TO BE PLACED ON A 6" BASE OF CRUSHER RUN FOR EASE OF INSTALLATION AND EVEN LOAD DISTRIBUTION.
- MINIMUM HEADROOM IS 3'-0". ADDITIONAL DEPTHS ARE AVAILABLE BY EXTENSION SECTIONS.

<b>4'-0" x 4'-0" VARIABLE DEPTH FLATWALL PULL BOX</b>	
ORG. DWG. DATE <b>11-15-00</b>	REV. DWG. DATE



44 FPB