


IAPMO RESEARCH AND TESTING, INC.

5001 East Philadelphia Street, Ontario, California 91761-2816 • (909) 472-4100 Fax (909) 472-4244 • www.iapmo.org



CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

Effective Date: February 2011 Void After: February 2012

Product: Grease Interceptors File No. 3007

Issued To: Jensen Precast
825 Steneri Way
Sparks, NV 89431

IDENTIFICATION: Grease interceptors shall be permanently and legibly marked with the manufacturer's name and/or trademark, model number, liquid retention capacity, month and year of manufacture, load limits and maximum recommended depth of earth cover in feet and inlet & outlet. Marking shall appear on a plate that has been permanently attached, molded, cast, or wetset onto the interceptor located on the left hand side of the inlet or on top of the interceptor near the inlet. Permanent markings shall be adequately protected from corrosion so as to remain permanent and readable over the life of the interceptor. Unit shall also bear the UPC® certification mark.



Chairman, Product Certification Committee


CEO, The IAPMO Group

For the most accurate and updated information please visit <http://pld.iapmo.org/3007>

This listing is for the period indicated herein and is void after the date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Reproduction of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing.





IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Page 2

Void After: February 2012

Product: Grease Interceptors

File No. 3007

Issued To: Jensen Precast


CHARACTERISTICS: Grease interceptors with two (2) compartments designed to remove grease from effluent and to retain grease until accumulations can be removed by pumping the interceptor.

Grease interceptors shall have a minimum size of 20 inches of manhole over the inlet and outlet compartments. It is recommended that a sample box be located at the outlet end of all grease interceptors so that the administrative authorities can periodically sample effluent quality. May be manufactured in concrete, steel, fiberglass reinforced polyester or polyethylene material.

To be installed in accordance with the manufacturer's instructions and the requirements of the latest edition of the Uniform Plumbing Code.

Products comply with the applicable sections of the latest edition of the Uniform Plumbing Code®. Manufactured in compliance with IAPMO/ANSI Z1001-2007.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.



IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Page 3

Void After: February 2012

Product: Grease Interceptors

File No. 3007

Issued To: Jensen Precast

MODELS:

INTERCEPTORS

HJ320-XX-YY, HJ500-XX-YY, HJ-750-XX-YY, HJ-1000-XX-YY,
HJ-1250-XX-YY, HJ-1500-XX-YY, HJ-2000-XX-YY, HJ-2500-XX-YY,
HJ-3000-XX-YY, HJ-4000-XX-YY, HJ-5000-XX-YY, JP-250SO,
JP-320-XX-YY, JP-500-XX-YY, JP-750-XX-YY, JP-1000-XX-YY,
JP-1200-XX-YY, JP-1500-XX-YY, JP-2000-XX-YY, JZ-2500-XX-YY,
JZ-3000-XX-YY, JZ-4000-XX-YY, JZ-5000-XX-YY


LEGEND: The "XX" following the model number will signify the manhole opening configuration (i.e. "EE": to designate a tank with two manhole openings, one over the inlet and one over the outlet). The "YY" that follows the manhole configuration will designate the interceptor's intended use (i.e. "G" for grease interceptor, "SO" for sand/oil interceptor).

LID CONFIGURATION

E - 1 opening; inlet or outlet end
EE - 2 openings; inlet and outlet end
ECE - 3 openings; inlet end, center and outlet end
ECBE - 4 openings; inlet end, center end, baffle, and outlet end

APPLICATION

G - Grease Interceptor
SO - Sand/Oil Interceptor



IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Page 4

Void After: February 2012

Product: Grease Interceptors

File No. 3007

Issued To: Jensen Precast

ADDITIONAL COMPANY INFO: