



■ ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES CONFIGURATION: FOR SPECIFIC CONFIGURATION, CALL JENSEN PRECAST.

MINIMUM EXCAVATION SIZE:
3'-2" x 4'-2" x DEPTH REQUIRED.

- (A) 6" TOP SECTION WT.= 200 Lbs.
- (B) 6" EXTENSION SECTION (OPTIONAL NOT SHOWN)
- (C) BOTTOM SECTION WT.= 900 Lbs.
- (D) 8" x 11" KNOCKOUT EACH END
- (E) 4" x 10" KNOCKOUT EACH SIDE
- (F) FOR COVERS: SEE COVER AND NECKING SECTION

- DESIGNED FOR PEDESTRIAN OR LIGHT TRAFFIC LOADING.
- ASSEMBLY TO BE PLACED ON A 6" BASE OF CRUSHER RUN FOR EASE OF INSTALLATION AND EVEN LOAD DISTRIBUTION.
- MINIMUM HEADROOM IS 2'-0". ADDITIONAL DEPTHS ARE AVAILABLE BY EXTENSION SECTIONS.

2'-0" x 3'-0" VARIABLE DEPTH FLAT WALL HAND HOLE	
ORG. DWG. DATE 11-15-00	REV. DWG. DATE



2436 FH