



MINIMUM EXCAVATION SIZE:  
5'-0" x 8'-6" x DEPTH REQUIRED.

■ ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES CONFIGURATION: FOR SPECIFIC CONFIGURATION, CALL JENSEN PRECAST.

- (A) 6" TOP SECTION WT.= 450 Lbs.
- (B) 6" EXTENSION SECTION (OPTIONAL NOT SHOWN)
- (C) INTERMEDIATE SECTION WT.= 2,860 Lbs.
- (D) BASE SECTION WT.= 3,000 Lbs.
- (E) 18" X 24" X 9" DEEP DUCT KNOCKOUT EACH END
- (F) 8" X 16" KNOCKOUT - TWO EACH SIDE
- (G) 6" DIA. SUMP KNOCKOUT
- (H) FOR COVERS: SEE COVER AND NECKING SECTION.
- (I) PULLING INSERT

- DESIGNED FOR PEDESTRIAN OR LIGHT TRAFFIC LOADING.
- ASSEMBLY TO BE PLACED ON A 6" BASE OF CRUSHER RUN FOR EASE OF INSTALLATION AND EVEN LOAD DISTRIBUTION.
- MINIMUM HEADROOM IS 3'-6". ADDITIONAL DEPTHS ARE AVAILABLE BY EXTENSION SECTIONS.

<b>3'-0" x 5'-0" VARIABLE DEPTH INTERCEPT PULL BOX</b>	
ORG. DWG. DATE <b>10-24-00</b>	REV. DWG. DATE



**3660 DIB**