


IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



IAPMO R&T Product Listing

This IAPMO R&T Listing is current as of 3/6/2019

Product: Prefabricated Gravity Grease Interceptors File No. 3007

Issued To: JENSEN PRECAST
825 STENERI WAY
SPARKS, NV 89431

Identification: Prefabricated gravity grease interceptors shall be permanently and legibly marked with the manufacturer's name and/or trademark, model number, working liquid volume (expressed at least in gallons), date (i.e. month and year), date code, or identifier traceable to the date of manufacture, maximum design load, maximum burial depth, inlet, and outlet. The markings shall be applied on permanently-affixed metal plates, etched, mechanically stamped, stamped with permanent (non-water-soluble) ink, or molded. Adhesive labels that comply with UL 969 shall also be considered permanent when placed on a surface that is not normally submerged in water. The product shall also bear the UPC® certification mark.

Characteristics: Prefabricated gravity grease interceptors made of concrete, fiber reinforced polyester (FRP), thermoplastic, or steel. Grease interceptors with at least two (2) compartments designed to remove grease from effluent and to retain grease until accumulations can be removed by pumping the interceptor.

Grease interceptors shall have a minimum size of 20 inches of manhole over the inlet and outlet compartments. It is recommended that a sample box be located at the outlet end of all grease interceptors so that the administrative authorities can periodically sample effluent quality.

To be installed in accordance with the manufacturer's instructions and the requirements of the latest edition of the Uniform Plumbing Code.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)
International Plumbing Code (IPC®)

Products are in compliance with the following standard(s):

IAPMO/ANSI Z1001-2016

MODELS:

INTERCEPTORS

HJ-1000-XX-YY
HJ-1250-XX-YY
HJ-1500-XX-YY
HJ-2000-XX-YY
HJ-2500-XX-YY
HJ-3000-XX-YY
HJ320-EE-G
HJ-4000-XX-YY

HJ-5000-XX-YY
HJ500-XX-YY
HJ-750-XX-YY
JP-1000-XX-YY
JP-1200-XX-YY
JP-1500-XX-YY
JP-2000-XX-YY
JP-250SO
JP-320-XX-YY
JP4W1250-XX-YY
JP-500-XX-YY
JP-750-XX-YY
JZ-2500-XX-YY
JZ-3000-XX-YY
JZ-4000-XX-YY
JZ-5000-XX-YY
MU750-XX-YY
MU1000-XX-YY
MU1200-XX-YY
MU1500 -XX-YY

LEGEND: The "XX" following the model number will signify the manhole opening configuration (i.e. "EE: to designate a tank with two manhole openings, one over the inlet and one over the outlet). The "YY" that follows the manhole configuration will designate the interceptor's intended use (i.e. "G" for grease interceptor, "SO" for sand/oil interceptor).

LID CONFIGURATION

E - 1 opening; inlet or outlet end
EE - 2 openings in inlet and outlet end
ECE - 3 openings; inlet end, center and outlet end
ECBE - 4 openings; inlet end, center end, baffle, and outlet end

APPLICATION

G - Grease Interceptor
SO - Sand/Oil Interceptor

This information was valid on 3/6/2019.