



■ ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES CONFIGURATION: FOR SPECIFIC CONFIGURATION, CALL JENSEN PRECAST.

MINIMUM EXCAVATION SIZE:  
5'-6" x 8'-0" x DEPTH REQUIRED.

- (A) 12" TOP SECTION WT.= 1,720 Lbs.
- (B) EXTENSION SECTIONS AVAILBLE.
- (C) 36" BOTTOM SECTION WT.= 5,200 Lbs.
- (D) 12" WIDE X 12" TALL PIPE KNOCKOUT ON EACH END WALL, CUSTOM SIZES AVAILBLE UPON REQUEST.
- (E) FOR COVERS: SEE COVER AND NECKING SECTION.

- DESIGNED FOR PEDESTRIAN OR LIGHT TRAFFIC LOADING.
- PLEASE CALL WITH DEPTH REQUIREMENTS, OTHER SIZES ARE AVAILBLE THAN WHAT IS SHOWN.

<b>4'-0" x 6'-6" VARIABLE DEPTH FLAT WALL WATER / GAS VAULT</b>	
ORG. DWG. DATE <b>11-29-00</b>	REV. DWG. DATE



**W-466 SERIES**