



■ ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES CONFIGURATION: FOR SPECIFIC CONFIGURATION, CALL JENSEN PRECAST.

MINIMUM EXCAVATION SIZE:  
4'-5" x 7'-10" x DEPTH REQUIRED.

- (A) 6" TOP SECTION WT.= 230 Lbs.
- (B) 6" EXTENSION SECTION (OPTIONAL NOT SHOWN)
- (C) INTERMEDIATE SECTION WT.= 1,220 Lbs.
- (D) BASE SECTION WT.= 1,700 Lbs.
- (E) 14" X 14" X 14" DEEP DUCT KNOCKOUT EACH END
- (F) 8" x 16" KNOCKOUT - TWO EACH SIDE
- (G) SUMP - VARIOUS SIZES AVAILABLE
- (H) FOR COVERS: SEE COVER AND NECKING SECTION.
- (I) PULLING IRON

- DESIGNED FOR PEDESTRIAN OR LIGHT TRAFFIC LOADING.
- ASSEMBLY TO BE PLACED ON A 6" BASE OF CRUSHER RUN FOR EASE OF INSTALLATION AND EVEN LOAD DISTRIBUTION.
- MINIMUM HEADROOM IS 3'-0". ADDITIONAL DEPTHS ARE AVAILABLE BY EXTENSION SECTIONS.

<b>2'-6" x 4'-0" VARIABLE DEPTH INTERCEPT PULL BOX</b>	
ORG. DWG. DATE <b>10-24-00</b>	REV. DWG. DATE

**JENSEN**  
PRECAST®

**3048 DIB**